



Department of Education  
Region X-Northern Mindanao  
**DIVISION OF MALAYBALAY CITY**  
Corner Don Carlos Guingona Sts, Malaybalay City  
*Telefax # 088-81-2894, E-mail add: [depedmtybivcity@yahoo.com](mailto:depedmtybivcity@yahoo.com)*



**DIVISION MEMORANDUM**

No. 215, s. 2014

**TO: Education Program Supervisors/Division Coordinators  
Public Schools District Supervisors  
Public and Private Elementary and Secondary School Heads  
All Others Concerned  
This Division**

**FROM:  EDILBERTO L. OPLENARIA  
Schools Division Superintendent**

**SUBJECT: Conduct of Evaluation and Verification of all inspected schools by the  
Bureau of Fire Protection.**

**DATE: July 25, 2014**

---

In view of the Division Memorandum No. 137 s. 2014 dated April 28, 2014 re: **Conduct of Fire Safety Inspections to Regional, Division, District Offices and Schools (Elem. & Secondary)** this office hereby informs that there will be an evaluation and verification by the BFD Task Force in all schools inspected within the month of July to August. Prior to their visit they will coordinate with the Public Schools District Supervisors and Secondary School Heads.

Attachment are as follows :

The Task Force Composition - Enclosure A.  
Findings and Recommendation of the Inspection Team - Enclosure B

**For the information, guidance and compliance.**

alo/ELO 2014



Republic of the Philippines  
Department of the Interior and Local Government  
**BUREAU OF FIRE PROTECTION**  
Regional Headquarters No. 10  
Gumamela Extn, Caliputan, Ogeyan do Oro City  
Tel No. (0822) 723020, 711573, 711574



BFPXA-

01 July 2014

**REGIONAL ORDER**  
**NUMBER: 2014-067**

In the interest of the service, the following named BFP Officer/personnel of Bukidnon BFP Unit this region are hereby designated to compose the Task Force Evaluation and Verification of all inspected establishments, offices and schools within the Province of Bukidnon as indicated opposite their names effective this date, to wit:

<u>Rank/ Name</u>	<u>Designated as</u>
CINSP ALAN A CABOT	Team Leader, Task Force Evaluation and Verification
SFO3 Rodolfo A Bobanco Jr.	Assistant Team Leader
SFO3 Daniel N Pedrosa	Member
FO1 Christopher A Bloyo	Member
FO1 Laurence R Camhari	Member
FO1 Aldrin Paul P Ronolo	Member
xxx	xxx

xxx  
  
**LINDY C LAUZON**  
**SUPT (DSC) BFP**  
**Officer-In-Charge**



Republic of the Philippines  
Department of the Interior and Local Government  
**BUREAU OF FIRE PROTECTION**  
Regional Office 10  
Gumamela Ext., Carmen, Cagayan de Oro City  
Telefax. No. 08822-723020, 088-8807534



09 June 2014

**Dr. EDELBERTO I OPLINARIA**  
Schools Division Superintendent  
Department of Education (DepEd)  
Malaybalay City Division,  
Malaybalay City

**Dear Supt OPLINARIA:**

Greetings!

In consonance with DepEd Order No. 72 s 2012 dated August 31, 2012 re Continuing Fire Safety and Awareness Program (PSAP) in schools, this Office issued a directive to all Provincial Fire Marshals (PFM's) dated 14 April 2014 to intensify the conduct of fire safety inspection to educational occupancy particularly in the basic educational institution in which the said activity is also in compliance with the Oplan Balik Eskwela of the BFP.

Likewise, a letter forwarded to Dr INGRID G. RACOMA, Regional Director of DepEd dated 11 April 2014, informing the good Director that BFP-10 will conduct a fire safety inspection starting from the Offices of the DepEd Division, District, and schools.

In compliance with the directive of this Office, the Office of the Provincial Fire Marshal (OPFM) of Bukidnon submitted a report which covered the month of May 2014 with 27 schools and offices inspected under the supervision of the DepEd Division of Malaybaalay City.

Table 1 is the result of the inspection conducted by BFP units in Bukidnon based on the requirements provided by Republic Act (RA) 9514 or otherwise known as Fire Code of the Philippines of 2008.

**Table 1**  
**Violated Provisions of the Fire Code**

<b>Violations</b>	<b>Frequency</b>	<b>Percent</b>
No fire alarm system installed	27	100
No portable fire extinguisher	21	77.8
No passageway for firetruck	21	77.8
No standpipe system	15	55.6

Note: Multiple Response (n=27)

The data show that all schools inspected have no fire alarm system (100%) while 77.8% have no portable fire extinguisher and passageway for firetruck respectively. Fifteen schools or 55.6% have no installed standpipe system. This implies that the schools have not made the safety of children under the tutelage of their priority.

The abovementioned violations are based on the following provisions of the Implementing Rules and Regulations (IRR) of RA 9514:

1. "All buildings, structures and facilities shall be installed with portable fire extinguishers that are designed, installed and maintained in accordance with this Section. Fire extinguishers shall be installed even if the property is equipped with automatic

- sprinklers, standpipe and hose, or other fixed protection equipment." (Sec 10.2.6.7 para B of the IRR of RA 9514) In this case at least 1-unit of fire extinguisher in each classroom and administrative office.
2. Approved fire alarm facilities capable of being manually operated in accordance with Section 10.2.6.4 of this IRR shall be provided in every educational building. (Sec. 10.2.9.5 para D1 of the IRR of RA 9514)
  3. All educational buildings shall have adequate exit illumination in accordance with Section 10.2.5.11 of this IRR. Flexible plan and open plan buildings and buildings designed for night occupancy and portions of buildings having interior and windowless rooms, areas, and corridors, shall have emergency lighting. (Sec. 10.2.9.3 para A of the IRR of RA 9514)
  4. All educational buildings shall have signs designating the location of exits or the path of travel to reach them, in accordance with Section 10.2.5.12 of this IRR. (Sec. 10.2.9.3 para B of the IRR of RA 9514)
  5. The occupant load of educational buildings or any individual storey or section thereof for the purpose of determining exits shall not be less than one person for each one and nine-tenths square meters (1.9 m<sup>2</sup>) of net classroom area or four and six-tenths (4.6) square meters of net area of shops, laboratories, and similar vocational rooms. In dry nurseries where sleeping facilities are provided, the occupant load shall be not less than one person for each three and three tenths square meters (3.3 m<sup>2</sup>). (Sec. 10.2.9.1 para B1 of the IRR of RA 9514)
  6. Every room or space with a capacity of fifty (50) or more persons or over ninety three square meters (93 m<sup>2</sup>) in area shall have at least two (2) doorways as remote from each other as practicable. Such doorways shall provide access to separate exits, but, where egress is through corridors, shall open upon a common corridor leading to separate exits in opposite directions. (Sec. 10.2.9.2 para B1 of the IRR of RA 9514)
  7. Use of jumpers or tampering with electrical wiring or overloading the electrical system beyond its designated capacity or such other practices that would tend to undermine the fire safety features of the electrical system. (Sec. 11.0.0.1 para M of the IRR of RA 9514)
  8. Constructing gates, entrances and walkways to building components and yards, and temporary or permanent structures on public ways, which obstruct the orderly and easy passage of fire fighting vehicles and equipment. (Sec. 11.0.0.1 para B of the IRR of RA 9514)

Moreover, administrative sanctions shall be served to those violators as stipulated in Sec. 13.0.0.7 para A1 of the IRR of the Fire Code, to wit:

The owner, administrator, occupant or other person responsible for the condition of the building, structure and their premises or facilities who violates any provision of the Fire Code or any of its implementing rules and regulations shall be penalized by:

- i. Administrative fine of not exceeding Fifty thousand pesos (P50,000.00); or
- ii. Stoppage of operations or by closure of such buildings, structures and their premises or facilities which do not comply with the requirements; or
- iii. Both such administrative fine and closure/stoppage of operation to be imposed by the proper authorities.

In this regard, we are looking forward to your cooperation in facilitating the compliance of fire safety requirements of the Fire Code of the Philippines.

For the safety of our children and future leaders.


Very truly yours,

  
FSUPT LINDY C LAUZON, DSC  
Officer-In-Charge

**Republic of the Philippines**  
**Department of the Interior and Local Government**  
**BUREAU OF FIRE PROTECTION**  
**Region 10**  
**Malaybalay City Fire Station**  
**Melendez St., Malaybalay City**

May 20, 2014  
Date

**EDILBERTO L. OPLENARIA**  
Schools Division Superintendent  
DIVISION OF MALAYBALAY CITY  
Cor. Don Carlos Guingona St, Brgy. 4, Malaybalay City



**NOTICE TO COMPLY**

Sir/Madam:

This has reference to the Fire Safety Inspection conducted by SFO1 GREGORIO C SABANA, BFP, FO1 ALDRIN P RONOLO, BFP and FO1 JOWANIE C CASINABE, BFP dated May 2, 5, 6, 7, 8, 9 & 12, 2014 within your school under the Division of Malaybalay City wherein inspector's report revealed the existence of the following defects/deficiencies, in violation of Republic Act No. 9514 otherwise known as Fire Code of the Philippines of 2008.

**SOUTH DISTRICT (MAY 2, 2014)**

**BANGCUD ELEMENTARY SCHOOL**

Defects/Deficiencies	Grace Period
Old bldg. only one(1) door/single Exit (Sec. 10.2.9.2 (B) of 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**BANGCUD NATIONAL HIGH SCHOOL**

Defects/Deficiencies	Grace Period
Some doors swinging against the exit travel of flow (Sec. 10.2.9.2 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
In adequate fire fighting appliance	
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514

**PADERNAL ELEMENTARY SCHOOL**

Defects/Deficiencies	Grace Period
Single door more than fifty (50) pupils occupied every room	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
Pre-school room, convenience outlet have no coverd	
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

# ARCOTE ELEMENTARY SCHOOL SCHOOL

Defects/Deficiencies	Grace Period
Classrooms, office, computer lab and library has single door. All doors are swinging against the exit travel of flow	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

## MALAPGAP ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
Unfixed electrical wiring installation	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

## FAR EAST DISTRICT (MAY 5, 2014)

### LUNOCAN ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
Old bldg. only one(1) door/single Exit (Sec. 10.2.9.2 (B) of 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

### MIGLAMIN ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

### BUSDI ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**AS ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
Some doors swinging against the exit travel of flow (Sec. 10.2.9.2 of R.A. 9514)	15 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**BAGONG SILANG ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
Some doors swinging against the exit travel of flow (Sec. 10.2.9.2 of R.A. 9514)	15 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**BALANGBANG PRIMARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**LALAWAN ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
Some doors swinging against the exit travel of flow (Sec. 10.2.9.2 of R.A. 9514)	15 Days (Sec.13.0.0.6 (B-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**PAIWAIG ELEMENTARY SCHOLL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
Some doors swinging against the exit travel of flow (Sec. 10.2.9.2 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**CENTRAL ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
Some doors swinging against the exit travel of flow (Sec. 10.2.9.2 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**NORTH DISTRICT (MAY 7, 2014)**

**SUMPONG ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
Some doors swinging against the exit travel of flow (Sec. 10.2.9.2 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**KALASUNGAY CENTRAL ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
Some doors swinging against the exit travel of flow (Sec. 10.2.9.2 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**KAPITAN ANGEL ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
Some doors swinging against the exit travel of flow (Sec. 10.2.9.2 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**BAGANAO ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514



LOG ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
Some doors swinging against the exit travel of flow (Sec. 10.2.9.2 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

KIBALABAG ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
Some doors swinging against the exit travel of flow (Sec. 10.2.9.2 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**WEST DISTRICT (MAY 9, 2014)****MAGSAYSAY ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
Some doors swinging against the exit travel of flow (Sec. 10.2.9.2 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**MAPAYAG ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
Some doors swinging against the exit travel of flow (Sec. 10.2.9.2 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**BENDOLAN ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
Some doors swinging against the exit travel of flow (Sec. 10.2.9.2 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

ING ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**CENTRAL DISTRICT (MAY 12, 2014)**

IMBAYAO ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
Some doors swinging against the exit travel of flow (Sec. 10.2.9.2 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

shall have an approved maintenance & testing program by the bldg. in accordance with accepted standards (NFPA 72).

2. All portable fire extinguishers, shall be suitable for Class A (Ordinary Combustible), B (Flammable), & C (Electrical Equipment) hazards, inspected, maintained & installed seventy five (75) sq meter per extinguisher (Max Area) with suggested distributions:

3. All standpipes outlets shall be installed with standard boxes with double jacketed fire hoses 1 ½ Diameters, 50-100 FT with 1 ½ O Nozzle with sufficient water pressure.

4. All suppliers/installers of fire protection system & alarm system must have at least necessary permits/certificate from DTI-Bureau of Product Standards, LGU & Local Bureau of Fire Protection.

5. All electrical wirings & equipment shall be in accordance with the Philippine Electrical Code.

6. Constructing gate, entrances and walkways to building components and yards and temporary or permanent structures on public ways, which obstruct the orderly and easy passage of fire fighting vehicles and equipment.

7. Advise the owner/management to conduct regular fire drills or shall be held at least twice a years among employees and staff of the plant.

In this regard, you are hereby advised to comply/correct the above-mentioned deficiencies within the prescribed grace period otherwise Notice to Correct Violation with corresponding order to pay administrative fine shall be issued by this office.

Very truly yours,

  
**SRINSP PEDRO B. FELICILDA, BFP**  
City Fire Marshal

**"PAALALA: MAHIGPIT NA IPINAGBABAWAL NG PAMUNUAN NG BUREAU OF FIRE PROTECTION SA MGA KAWANI NITO ANG MAGBENTA O MAG-REKOMENDA NG ANUMANG BRAND NG FIRE EXTINGUISHER."**


Violator shall be apprehended pursuant to applicable provisions of RA 9514 or Fire Code of the Philippines of 2008

Republic of the Philippines  
Department of the Interior and Local Government  
**BUREAU OF FIRE PROTECTION**  
Region 10  
**Malaybalay City Fire Station**  
Melendez St., Malaybalay City

May 20, 2014  
Date

**EDILBERTO L. OPLENARIA**

Schools Division Superintendent  
DIVISION OF MALAYBALAY CITY  
Cor. Don Carlos Guingona St, Brgy. 4, Malaybalay City



**NOTICE TO COMPLY**

Sir/Madam:

This has reference to the Fire Safety Inspection conducted by FO3 NIEJEL CLIVE A NACARIO, BFP, and FO2 ASTROPHEL C MULET, BFP dated May 2,5,6,7,8,9 & 12, 2014 within your school under the Division of Malaybalay City wherein inspector's report revealed the existence of the following defects/deficiencies, in violation of Republic Act No. 9514 otherwise known as Fire Code of the Philippines of 2008.

**SOUTH DISTRICT (MAY 2, 2014)**

**CABANGAHAN ELEMENTARY SCHOOL**

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**SIMAYA ELEMENTARY SCHOOL**

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**SANALBAGAN ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**SAN MARTIN AGRO-INDUSTRIAL NATIONAL HIGH SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**SAN MARTIN ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**DAPULAN ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**CALAWAG ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**PAR EAST DISTRICT (MAY 5, 2014)**

**INDALASA ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**ST. PETER ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**KULAMAN ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**ZAMBOANGUITA ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**SILAE NATIONAL HIGH SCHOOL – ST. PETER ANNEX**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**BAR EAST DISTRICT (MAY 6, 2014)****MATANGPATANG ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**LANGASIHAN ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**MANAGOK NATIONAL HIGH SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**MANAGOK NATIONAL HIGH SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514



# MANAGOK NATIONAL HIGH SCHOOL – LALAWAN ANNEX

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

# MANAGOK NATIONAL HIGH SCHOOL – MIGLAMIN ANNEX

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

# MANAGOK NATIONAL HIGH SCHOOL – LALAWAN ANNEX

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

# MANAGOK ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

# SAWAGA ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**NORTH DISTRICT (MAY 7, 2014)****KILAP-AGAN ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**TAGILANAO ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**TINTINAAN ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**CANDIISAN ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**CAN-AYAN INTEGRATED SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**NORTH DISTRICT (MAY 8, 2014)****DALWANGAN ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514)
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514)
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514)
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)

**NEW ILOCOS ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514)
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514)
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514)
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)

**PATPAT ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514)
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514)
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514)
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)

**WEST DISTRICT (MAY 9, 2014)****PANAMUCAN ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514)
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514)
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)

MABUHAY ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

SAN JOSE ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

BUKIDNON NATIONAL HIGH SCHOOL – CASISANG ANNEX

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

AIRPORT VILLAGE ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

AGLAYAN ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514

No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514)
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514)
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)

#### SAN JOSE ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514)
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514)
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)

#### BUKIDNON NATIONAL HIGH SCHOOL – CASISANG ANNEX

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514)
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514)
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)

#### AIRPORT VILLAGE ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514)
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B <sub>1</sub> ) of RA 9514)
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514)
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)

#### AGLAYAN ELEMENTARY SCHOOL

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514)
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514)
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514)

**BUKIDNON NATIONAL HIGH SCHOOL – AGLAYAN ANNEX**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**CENTRAL DISTRICT (MAY 12, 2014)**

**NATID-ASAN ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**LAGUITAS ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

**CENTRAL DISTRICT (MAY 14, 2014)**

**BCT ELEMENTARY SCHOOL**

<b>Defects/Deficiencies</b>	<b>Grace Period</b>
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

Defects/Deficiencies	Grace Period
No Fire Alarm System System (Sec. 10.2.9.5 (D) of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3b) of RA 9514
No access road for orderly and easy passage of Fire Fighting vehicles and Equipment (Sec. 11.0.0.1 para B of R.A. 9514)	3 Days (Sec.13.0.0.6 (B-1) of RA 9514
No fire fighting appliance installed (Sec. 10.2.6.7 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-1) of RA 9514
No Standpipe System Installed (Sec. 10.2.15.3 para "D-3" of RA 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514
No Latest Certificate of Electrical Inspection (Sec. 10.5.6.4 of R.A. 9514)	15 Days (Sec.13.0.0.6 (E-3) of RA 9514

1. The fire alarm system shall have an approved maintenance & testing program by the bldg. Management in accordance with accepted standards (NFPA 72).

2. All portable fire extinguishers, shall be suitable for Class A (Ordinary Combustible), B (Flammable), & C (Electrical Equipment) hazards, inspected, maintained & installed seventy five (75) sq meter per extinguisher (Max Area) with suggested distributions:

3. All standpipes outlets shall be installed with standard boxes with double jacketed fire hoses 1 ½ Diameters, 50-100 FT with 1 ½ O Nozzle with sufficient water pressure.

4. All suppliers/installers of fire protection system & alarm system must have at least necessary permits/certificate from DTI-Bureau of Product Standards, LGU & Local Bureau of Fire Protection.

5. All electrical wirings & equipment shall be in accordance with the Philippine Electrical Code.

6. Constructing gate, entrances and walkways to building components and yards and temporary or permanent structures on public ways, which obstruct the orderly and easy passage of fire fighting vehicles and equipment.

7. Advise the owner/management to conduct regular fire drills or shall be held at least twice a years among employees and staff of the plant.

In this regard, you are hereby advised to comply/correct the above-mentioned deficiencies within the prescribed grace period otherwise Notice to Correct Violation with corresponding order to pay administrative fine shall be issued by this office.

Very truly yours,

  
**SRINSP PEDRO B FELICILDA, BFP**  
 City Fire Marshal

**"PAALALA: MAHIGPIT NA IPINAGBABAWAL NG PAMUNUAN NG BUREAU OF FIRE PROTECTION SA MGA KAWANI NITO ANG MAGBENTA O MAG-REKOMENDA NG ANUMANG BRAND NG FIRE EXTINGUISHER."**

Violator shall be apprehended pursuant to applicable provisions of RA 9514 or Fire Code of the Philippines of 2008